



**Formulated For The Professionals**  
**Adhesives & Sealants**

# VT-219 Fire Rated Silicone Sealant

## 100% Neutral Silicone Sealant

A one-component, gun grade neutral silicone sealant formulated to form elastomeric fire retardant seals in construction applications.

### Applications:

Recommended for firestop sealing of interior and exterior building and construction joints, where a fire rating of up to 4 hours is required.

In addition, it may be used to seal vertical and horizontal joints between metals, masonry, concrete and other common construction materials.

### Applicable Test / Standard:

1. BS EN 1366-4:2006 Fire Resistance Tests
2. AS 1530.4:2014 Methods for Fire Tests on Building Materials
3. ASTM C920 and ASTM C719, Type S, Grade NS, Class 50, NT, A
4. Low VOC - USEPA Method 24 under SCAQMD Rule 1168 & USEPA Method 310
5. SIRIM Product Certification Licence Scheme
6. ESL Certification

**Available colours:** Matte Black and Matte Grey

Item Code	Content	Carton Quantity
VT-219	300 ml Cartridge	24 / Carton
VT-219S	600 ml Sausage	20 / Carton



ACP FACADE



ACP WALL



UNDERGROUND  
TUNNEL JOINTS



Certification No.:  
**ESL-24-11667**  
EN1366-4  
Exova Warringtonfire



**SIRIM**  
Certified to: ASTM C 920 : 2018  
Certification No.: PC013998



### Features

- Fire rating up to 4 hours
- $\pm 50\%$  movement capability
- Malaysian Fire & Rescue Department (Jabatan Bomba dan Penyelamat) certified
- Excellent weather and UV resistance
- Excellent adhesion to most substrates
- Does not contain halogenated material
- Matte finish



**VITAL TECHNICAL SDN. BHD.** Co.No.: 200201021558 (589221-K)

+603 6094 2088 (Tel) +603 6099 2930 (Fax)

sales@vitaltechnical.com

www.vitaltechnical.com



A member of

**NIPPON PAINT**

No, 93, Jalan Industri 3/3, Rawang Integrated Industrial Park, 48000 Rawang, Selangor Darul Ehsan, Malaysia.